

Valve connectors - SACC-V-4CON-PG9/A - 1527883

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Valve connectors, 4-position, Valve connector A, Screw connection, cable gland Pg9, external cable diameter



Key Commercial Data

Packing unit	1 STK
GTIN	4 017918 980955
GTIN	4017918980955

Technical data

Dimensions

External diameter	6 mm 8 mm
Ambient conditions	

Ambient temperature (operation)	-30 °C 100 °C (connector)
Degree of protection	IP65

General

Rated current at 40°C	10 A
Rated voltage	250 V
Number of positions	4
Insulation resistance	\geq 100 M Ω
Status display	No
Protective circuit/component	Unwired
Overvoltage category	II
Degree of pollution	3
Connection method	Screw connection
Conductor cross section	0.34 mm² 1.5 mm²
Conductor cross section AWG	22 16
Insertion/withdrawal cycles	50 Valve connector



Valve connectors - SACC-V-4CON-PG9/A - 1527883

Technical data

Material

Flammability rating according to UL 94	НВ
Valve plug contact material	CuSn
Valve plug contact surface material	Ni
Valve plug contact insert material	PA6
Material housing valve plug	PA6
Sealing material	NBR (Flat gasket)
	TPE (Screw connection)

Standards and Regulations


Connection in acc. with standard	UL
Flammability rating according to UL 94	НВ


Environmental Product Compliance

REACh SVHC	Lead 7439-92-1
China RoHS	Environmentally friendly use period: unlimited = EFUP-e
	No hazardous substances above threshold values

Drawings

Dimensional drawing





Approvals

Approvals

Approvals

EAC

Ex Approvals

Approval details



Valve connectors - SACC-V-4CON-PG9/A - 1527883

Approvals



Phoenix Contact 2018 © - all rights reserved http://www.phoenixcontact.com

PHOENIX CONTACT GmbH & Co. KG Flachsmarktstr. 8 32825 Blomberg Germany Tel. +49 5235 300 Fax +49 5235 3 41200

http://www.phoenixcontact.com

08/20/2018 Page 3 / 3